

水質検査結果書

福環保協発第 W1700703 号

勝山市長 山岸 正裕 様

平成 29年 9月 26日 発行

厚生労働大臣登録品質検査機関(193号)

福井県環境保全協業組合

理事長 三木 和則

福井県福井市角折町第8号2番地

TEL (0776) 35 4001

FAX (0776) 35 - 2140

採 取 年 月 日 及 び 時 刻	平成 29 年 9 月 7 日 13 時 35 分	気温 23.9 ℃ 水温 22.0 ℃	
採 水 地 点	北郷配水区	天候	前日
	—		当日
採 水 者	高間 幸範		—
検 体 の 種 別	上水道	残 留 塩 素	0.1mg/L

検 査 項 目	検 査 結 果		基 準 値	定量下限値	検 査 方 法
一般細菌	0	個/mL	100 個/mL以下	0	告示別表第1
大腸菌	陰性		検出されないこと	—	告示別表第2
塩化物イオン	4.7	mg/L	200 mg/L以下	0.2	告示別表第13
有機物(全有機炭素 (TOC))	0.3	未満 mg/L	3 mg/L以下	0.3	告示別表第30
pH値	6.9	(20℃)	5.8以上8.6以下	—	告示別表第31
味	異常なし		異常でないこと	—	告示別表第33
臭気	異常なし		異常でないこと	—	告示別表第34
色度	0.5	未満 度	5 度以下	0.5	告示別表第36
濁度	0.2	未満 度	2 度以下	0.2	告示別表第41
	以 下 余 白				
				</	